


**ADDENDUM NO. 3
TO THE
CONTRACT DOCUMENTS
FOR**

**Silver Lake Water and Sewer District of Snohomish County, Washington
HIGHLANDS EAST LIFT STATION REHABILITATION**

THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS TO THE SAME EXTENT AS THOUGH IT WERE ORIGINALLY INCLUDED THEREIN.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON THE BID PROPOSAL FORM. BID PROPOSALS THAT FAIL TO ACKNOWLEDGE ALL ADDENDA MAY BE CONSIDERED IRREGULAR AND MAY BE REJECTED.

ISSUED THIS 16TH DAY OF DECEMBER 2024.



12/16/2024

Conсор
600 University Street, Suite 300
Seattle, WA 98101

ITEM NO. 1 – Control Building Ceiling

1. **CLARIFICATION** Ceiling for the control building shall be plywood decking, coating per Specification Section 09 90 00.

END OF ADDENDUM NO. 3