

**ADDENDUM NO. 1  
TO THE  
CONTRACT DOCUMENTS  
FOR**

**Silver Lake Water and Sewer District of Snohomish County, Washington  
HIGHLANDS EAST LIFT STATION REHABILITATION**

THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS TO THE SAME EXTENT AS THOUGH IT WERE ORIGINALLY INCLUDED THEREIN.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON THE BID PROPOSAL FORM. BID PROPOSALS THAT FAIL TO ACKNOWLEDGE ALL ADDENDA MAY BE CONSIDERED IRREGULAR AND MAY BE REJECTED.

ISSUED THIS 5TH DAY OF DECEMBER 2024.



**Conzor**  
600 University Street, Suite 300  
Seattle, WA 98101

### **ITEM NO. 1 – Updates to Bid Proposal**

1. **REVISE** the quantity of Bid Item 28. Curb and Gutter to 33 LF.

### **ITEM NO. 2 – Liquidated Damages**

1. **REVISE** the last sentence of Section 4.4 of the General Conditions to read as follows:

The amount of daily liquidated damages shall be \$1,000 per working day rather than the formula provided under Std. Spec. 1-08.9.

### **ITEM NO. 3 – Limit Switch**

1. **REVISE** Detail 2/E-9 to specify Allen-Bradley 802MC Series Limit Switch or approved equivalent.

### **ITEM NO. 4 – Air Valves**

1. **CLARIFICATION** Combination Air-Vacuum Valves are specified in Section 40 05 51.72, 2.4.

### **ITEM NO. 5 – Flange Bolts**

1. **ADD** the following note to Section 40 05 13, 2.1:

C. All flange bolts shall be 316 stainless steel.

### **ITEM NO. 6 – Ductile Iron Pipe**

1. **REMOVE** references to Specification 33 11 10 in Section 33 13 00, 1.1.C.1. and Section 40 05 13, 2.2.A.
2. **REPLACE** Section 40 05 13,2.2.A with the following:

A. See Section 33 31 10, 2.1.B.

### **ITEM NO. 7 – Pipe and Fitting Linings**

1. **REPLACE** Section 33 31 10,2.1.B.6.c with the following:

Lining: Ceramic epoxy, per requirements in Section 09 90 00.

### **ITEM NO. 8 – Duckbill Check Valve**

1. **REPLACE** Keynote 37 on sheet M-1 with the following:

4" ELASTOMERIC CHECK VALVE, RED VALVE TF-2 OR APPROVED EQUIVALENT

**END OF ADDENDUM NO. 1**