

**ADDENDUM NO. 2
TO THE
CONTRACT DOCUMENTS
FOR**

**Silver Lake Water and Sewer District of Snohomish County, Washington
HIGHLANDS EAST LIFT STATION REHABILITATION**

THIS ADDENDUM IS HEREBY MADE A PART OF THE CONTRACT DOCUMENTS TO THE SAME EXTENT AS THOUGH IT WERE ORIGINALLY INCLUDED THEREIN.

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ALL ADDENDA ON THE BID PROPOSAL FORM. BID PROPOSALS THAT FAIL TO ACKNOWLEDGE ALL ADDENDA MAY BE CONSIDERED IRREGULAR AND MAY BE REJECTED.

ISSUED THIS 11TH DAY OF DECEMBER 2024.



12/11/2024

Conсор
600 University Street, Suite 300
Seattle, WA 98101

ITEM NO. 1 – Change Datum to NAVD88

1. **FYI** The plans were developed utilizing NGVD 29 consistently across the plan set. The District's standard is NAVD88 and so a conformed document set will be issued to the selected contractor with elevations shifted to NAVD88. The shift has no impact on bid quantities.

ITEM NO. 2 – Air Valves

1. **CLARIFICATION** Combination Air-Vacuum Valves in the Valve Vault are 2-inch diameter.
2. **REVISE** Specification Section 40 05 51.72, 2.4.A.1. to read as follows:
 1. Inlet Size: 2-inch diameter.

END OF ADDENDUM NO. 2